

QUALITY ALERT

Created By: Sam James (Quality Manager)

Authorised By: Michael Clorley (Director)

Business:	MIDA Civil Engineering Ltd		ALERT
Title:	Downpipe Brown Caps	Reference No:	QA23
Issued By:	Sam James	Issue Date:	24 th June 2024
Type of Alert:	Quality & Compliance		
Subject:	Downpipe caps to be below Finished Ground Levels		
Operatives Affected:	Groundworkers		
Details:	Check when installing that downpipe caps are low enough to be a minimum 75mm below finished ground level		
Action Required:	Check before Oversight handover the caps are low enough to be a minimum 75mm below Finished ground level and check again at Landscaping stage if any underbuild has been fully taken into account and follow OS - 5.7 Plumbers Connection at RWPs Bad practice examples shown on a drive and landscaping situations where the brown cap should have been set lower		
Further Information:	MIDA OS - 5.7 Plumbers Connection at RWPs		
Method for Communication:	Briefing by Site Manager to groundworkers via TBT Alert		