


QUALITY ALERT

Created By: Sam James (Quality Manager)

Authorised By: Michael Clorley (Director)

Business:	MIDA Civil Engineering Ltd		ALERT
Title:	Cold Bridging on cavity wall insulation DW Homes detail	Reference No:	QA28
Issued By:	Sam James	Issue Date:	22nd Aug 2024
Type of Alert:	Quality & Compliance		
Subject:	The correct installation of TE Platinum Board on DW Homes sites		
Operatives Affected:	Groundworkers		
Details:	The TE Platinum Board insulation needs to be installed and cut to avoid any cold bridging points with the silver side facing outwards		
Action Required:	Install with mitered cuts in bay windows and butted tight in all cases with no gaps and propped 50mm of outside skin to leave a 50mm cavity		
Further Information:	Alreflex Platinum Cavity Wall Installation Guide Alreflex Platinum Product Data sheet Barratt/David Wilson site specific detail	Poor Installation 	
Method for Communication:	Briefing by Site Manager to groundworkers via TBT Alert		