

QUALITY ALERT

Created By: Sam James (Head of ETQ)

Authorised By: James Brown (Director)

Business:	MIDA Civil Engineering Ltd		ALERT
Title:	LWoH Formation Preparation	Reference No:	QA34
Issued By:	Sam James	Issue Date:	14 th Jan 2025
Type of Alert:	Quality & Compliance		
Subject:	Formation Preparation tolerances		
Operatives Affected:	Groundworkers		
Details:	It has been noted by the Infrastructure Project manager that the formation preparation is out of tolerance. The tolerance to be worked to is +20mm and -30mm of formation level The contract detail requires minimum 350mm lap of Tensar HX165 Geogrid where used in Type 2 carriageways specific to LWoH  Formation Preparation out of Tolerance at LWoH		
Action Required:	Formation to be proof rolled to align with Clause 616 note as below: 616 (02/16) Preparation and Surface Treatment of Formation 1 (02/16) The formation shall, after completion of any subgrade drainage, and immediately before laying sub base on areas of completed formation, have a surface level tolerance within +20 mm and -30 mm, or other level of tolerance defined		
Further Information:	• SHW 600 clause 616 • DWG 24-023-10306 C7		
Method for Communication:	Briefing by Site Manager to groundworkers via TBT Alert		