

QUALITY ALERT

Created By: Ben James (Quality Manager)

Authorised By: James Brown (Director)

Business:	MIDA Civil Engineering Ltd		ALERT
Title:	Ensure waters are capped at all times	Reference No:	QA41
Issued By:	Ben James	Issue Date:	9 th June 2025
Type of Alert:	Quality & Compliance		
Subject:	Capping off water		
Operatives Affected:	Engineers and R&S Site managers and operatives		
Details:	A client informed us that another contractor scored a 2 on a CQR report as they did not install the correct rubber bung in the duct. Please can we ensure we continue to put the bung in to stop animals and rubble getting within the duct and pipe. 		
Action Required:	The Quality Alerts for these items are on the Knowledge Hub and details can be found in MIDA OS/OI Standards, take time to check your sites for these defects and carry out TBT for the above to reinforce with your teams the requirements		
Further Information:	Quality Alerts on MIDA Knowledge Hub MIDA Operational Standards & Instructions		
Method for Communication:	Briefing by Site Manager to groundworkers via TBT Alert		