


QUALITY ALERT

Created By: Ben James (Quality Manager)

Authorised By: James Brown (Director)

Business:	MIDA Civil Engineering Ltd		ALERT
Title:	Correct use of spacers on ring Beams	Reference No:	QA47
Issued By:	Sam James	Issue Date:	10 th Sept 2025
Type of Alert:	Quality & Compliance		
Subject:	Correct use of Spacers on Ring Beam		
Operatives Affected:	Site managers and operatives		
Details:	When side spacing Ring Beams you must ensure spacers are on every other link and use flat base clip on spacers not Tric Trac linear spacers and do not tie tying wire all the way from outside of groundbeam to the reinforcement as this can track water from the surrounding ground to the reinforcement just clip the spacers on		
Action Required:	Avoid using tric trac as below and use plastic spacers correctly spaced		
Further Information:	BS7973-2- Spacers and Chairs for steel reinforcement and tying of reinforcement		TRIC TRAC
Method for Communication:	Briefing by Site Manager to groundworkers via TBT Alert		