

QUALITY ALERT

Created By: Ben James (Quality Manager)

Authorised By: James Brown (Director)

Business:	MIDA Civil Engineering Ltd		ALERT
Title:	Shingle Under Pipes	Reference No:	QA51
Issued By:	Ben James	Issue Date:	05-02-26
Type of Alert:	Quality & Compliance		
Subject:	Having The Correct Bed Under Pipes		
Operatives Affected:	Site Managers		
Details:	We are increasingly getting picked up on not having the NHBC requirement of 100mm depth for pipe bedding. With the 825mm gauge which is majority across the company the pipes tend to be on the floor of the foundation which means straight off the footing we don't have the depth.		
Action Required:	Straight off the foundation we need to step the ground down 100mm and blend it out as the further you go back with the fall of the pipe you will re gain the 100mm requirement.		
Further Information:			
Method for Communication:	Briefing by Site Manager to groundworkers via TBT Alert		