

Business:	MIDA Civil Engineering Ltd		ALERT
Title:	EPS Panel Cuts Less Than 300mm	Reference No:	QA53
Issued By:	Ben James	Issue Date:	22-5-26
Type of Alert:	Quality & Compliance		
Subject:	EPS Panel Cuts		
Operatives Affected:	Site Managers		
Details:	When going around sites we are noticing more cuts less than 300mm on the EPS Panels, please ensure all cuts are 300mm and above as per spec.  		
Action Required:	When placing panels check when cutting to allow the minimum 300mm.		

QUALITY ALERT

Created By: Ben James (Quality Manager)

Authorised By: James Brown (Director)

**Further
Information:****Method for
Communication:**Briefing by Site Manager to groundworkers via TBT
Alert