

QUALITY ALERT

Created By: Ben James (Quality Manager)

Authorised By: James Brown (Director)

Business:	MIDA Civil Engineering Ltd		ALERT
Title:	Tobermore Coping Fixing	Reference No:	QA55
Issued By:	Sam James	Issue Date:	22/06/26
Type of Alert:	Quality & Compliance		
Subject:	Tobermore Coping Fixings		
Operatives Affected:	Site Managers Contracts managers		
Details:	Tobermore specify the copings are fixed with Construction Adhesive Typically a CT-1 <u>NOT</u> Morter- On Taylor Wimpey sites only these need mechanically fixing to their specification	Tobermore Notes	
		Cap to be fixed with suitable exterior construction adhesive Secure the copings in place using a high quality exterior grade construction adhesive such as CT1 Power N Grab bond, Loctite Fast Grab Premium, Soudal Fix All - High Tack or equivalents	
Action Required:	Ensure all copings for Tobermore walls are fixed with construction adhesives on all sites with Taylor Wimpey sites mechanically fixed		
Further Information:			
Method for Communication:	Briefing by Site Manager to groundworkers via TBT Alert		