

QUALITY ALERT

Created By: Quality Manager

Authorised By: James Brown (HSEQT Director) / Danny Murphy (Director)

Business:	MIDA Civil Engineering Ltd		ALERT
Title:	Site Cap Levels in Floors	Reference No:	QA006
Issued By:	Sam James	Issue Date:	24/5/23
Type of Alert:	Quality		
Subject:	Setting of internal pipe caps in floors		
Operatives Affected:	Groundworkers		
Details:	Site caps set too low in relation to floor surface levels.		
Action Required:	Ensure site caps are set to the correct levels in relation to floor surface finish.		
Further Information:	N/A		
Method for Communication:	Briefing by Site Manager and documented on TBT sheet. Alert to be put up in site office.		